



Flächenkategorie											
Vb-Nr.	Raumbezeichnung	Sys N	h _{eff}	da x s m	V m³	Δp hPa	τ K	φ ₂₅ W/m²	T _{g,m,25} °C	φ ₂₅ W/m²	T _{g,m,25} °C
01.06/1	Schulungsraum	Fbh	1	115,93	1762,00	73,5	46,9	10,7	47,4	15,0	24,6
01.06/2	Schulungsraum	Fbh	1	115,93	1762,00	73,5	46,9	10,7	47,4	15,0	24,6
01.06/3	Schulungsraum	Fbh	1	115,93	1762,00	73,5	46,9	10,7	47,4	15,0	24,6
01.06/4	Schulungsraum	Fbh	1	119,33	1762,00	73,5	48,5	10,7	47,4	15,0	24,6
01.06/5	Schulungsraum	Fbh	1	119,33	1762,00	73,5	48,5	10,7	47,4	15,0	24,6
01.06/6	Schulungsraum	Fbh	1	115,92	1762,00	73,5	46,8	10,7	47,4	15,0	24,6
01.07/1	Lagerung Schlus	Fbh	1	59,82	1762,00	72,6	23,7	8,0	39,3	30,0	23,8
01.08/1	Archiv	Fbh	1	17,97	1762,00	51,1	12,1	14,8	39,5	30,0	23,9
01.09/1	Drucker	Fbh	1	26,39	1762,00	74,2	1,900	24,2			24,2
01.10/1	Drucker	Fbh	1	36,52	1762,00	25,4	2,8	14,6	40,2	30,0	23,9
01.11/1	Server	Fbh	1	37,19	1762,00	21,5	2,4	14,0	41,8	30,0	24,1